



**Revised Bid Packet  
Macon Lake Dam Rip Rap  
Bids Due:  
Tuesday, June 17, 2021  
by 1:00 pm**

Macon Municipal Utilities is requesting bids to calculate, haul, and place a well graduated 8" stone to 1,327 feet of shoreline along the Macon City Lake Dam near 1201 Noll Drive, Macon, Missouri. Bids are to be delivered to the MMU Business Office at 106 W. Bourke Street, Macon, MO 63552 by **1:00 pm on Thursday, June 17, 2021.**

Successful bidder must purchase a City Business License. This License may be obtained from the office of the City Collector located at 106 W. Bourke Street, Macon, MO. 63552. The fee is \$50.00.

Successful bidder is requested to carry insurance coverage for the duration of the project in the following amounts. Lower coverages may be accepted.

- **\$1,000,000 Liability**
- **\$2,000,000 Aggregate**
- **\$5,000 Medical**
- **Workers' Compensation**

The successful bidder will be required to provide a certificate of insurance listing Macon Municipal Utilities as additional insured, and sign a hold-harmless agreement. Successful bidder shall require same of all subcontractors. Each bidder must inform himself fully of the conditions relating to the composition of the project and the employment of labor thereon. Failure to do so will not relieve the successful bidder of his obligation to furnish all material and labor necessary to carry out the provisions of this project.

Submission of bid confirms bidder agrees that they understand, and agree to abide by all terms and conditions, responsibilities and specifications of the project. Bidder will be presumed to have inspected the site and to be thoroughly familiar with the project requirements. The failure or omission to do so, shall in no way relieve any bidder from any obligation in respect to his bid.

Bidders are informed that pursuant to Section 285.530, RSMo, as a condition of the award of any contract in excess of five thousand dollars (\$5,000), the Bidder shall, by sworn affidavit and provision of documentation, affirm its enrollment and participation in a federal work authorization program with respect to the employees working in connection to the contracted services. Bidder shall also sign an affidavit affirming that it does not knowingly employ any person who is an unauthorized alien in connection to the contracted services.

This project is not expected to be subject to **prevailing wage** rates. Once work has commenced, the work shall be continuous and the contractor shall not remove their personnel and/or equipment from the City until the work has been completed and approved by City personnel.

The bidder's attention is directed to the fact that all applicable State Laws, Municipal Ordinances, and the rules and regulations of all authorities having jurisdiction over composition of the project shall apply to the contract throughout, and they will be deemed to be included in the contract the same as though herein written out in full.

Macon Municipal Utilities shall be the final judge of the quality and suitability of the work, materials, and methods of construction for the purposes for which they are used. Should they fail to meet approval they shall be forthwith reconstructed, made good, replaced, and or corrected by the contractor at his own expense. Rejected materials shall be removed immediately from the site.

Macon Municipal Utilities reserves the right to reject any or all bids.

**REVISED PROJECT SPECIFICATIONS**

Macon Municipal Utilities (MMU) is accepting bids to calculate, haul, and place a well graduated 8" stone to 1,327 feet of shoreline along the Macon Lake Dam near 1201 Noll Drive, Macon, Missouri. Contractor will haul and place rock with an excavator in a 6-foot width along the shoreline, starting at water line and working up the dam. Rock calculations should use 24-inch depth as an average. Please refer to the attached rock graduation sheet provided when calculating the rock to be used. Rock may be attained from any quarry but needs to be equivalent to the that on the specified graduation sheet. Contractor will be allowed to travel across the top of the dam to dump rock for the excavator that is placing the rock along the waterline. Before work is to begin the top of the dam elevation shall be shot and recorded. After heavy equipment work is complete, the contractor is responsible for providing dress up of the disturbed soil and grass. As part of dress up it is important that the top of the dam be returned to its original elevation before the project began. If selected, work shall be performed in the Summer/Fall of 2021 during dry conditions. The contractor will be permitted to stock pile rock for the project on MMU property one-half mile to the west along the outer road. If additional rock is needed, please provide a quote for time and materials to complete the project. Questions can be directed to Matt Meisner at (660) 676-6168 or mmeisner@gommu.com.

**Bid Tab:**

Total amount of well graduated 8" stone \$ \_\_\_\_\_

Hauling, Placement, and Dress up \$ \_\_\_\_\_

Total \$ \_\_\_\_\_

**Alternate Bid:**

Additional well graduated 8" stone, per ton \$ \_\_\_\_\_

Hauling and Placement, per ton \$ \_\_\_\_\_

Acknowledgement of Revised Specifications (Initial) \_\_\_\_\_

Bidder: \_\_\_\_\_

Contact Info: \_\_\_\_\_

The contractor shall, before any work is accepted by Macon Municipal Utilities, remove from the job site all litter and trash of any kind, and shall leave the area in good condition and ready for its use.

# Summit Materials

## Quality Test Report

Plant 010201-Huntsville Quarry  
Product 232-Gabion Stone  
Specification



### Sample Information

Sample No 523671586 Split Sample   
Date Sampled 05/11/2021 09:13 Resample   
Sampled By Patrick White  
Type Investigative  
Method Stockpile  
Location Huntsville Quarry  
Ledge Ledge 1B-5B Huntsville

### Gradation Results

Date Completed 05/11/2021 09:13 Tested By Patrick White

Unit	Moist Mass	Dry Mass	Wash Mass	Moisture %	Wash Loss %	Procedure
g	3260.00	3260.00	3260.00	0.0	0.0	

Sieve	Mass Retained	Cum Mass Retained	Ind % Retained	% Retained	% Passing	Target	Specification	Comment
10" (250mm)	0.00	0.00	0.0	0.0	100.0			
9" (225mm)	160.00	160.00	4.9	4.9	95.1			
8" (200mm)	260.00	420.00	8.0	12.9	87.1			
7" (175mm)	860.00	1280.00	26.4	39.3	60.7			
6" (150mm)	740.00	2020.00	22.7	62.0	38.0			
5" (125mm)	520.00	2540.00	16.0	77.9	22.1			
4" (100mm)	220.00	2760.00	6.7	84.7	15.3			
Pan	500.00	3260.00	15.34	100.00	0.00			